



CHESTER P. VOISIN  
*President*  
JOHN PIZZOLATTO  
*Vice-President*  
CLIFTON J. STOUFFLET  
*Secretary*

STEPHEN HORNSBY  
VINCENT CELESTIN  
CHARLES BROWN, SR.  
TERI CHATAGNIER  
WILBERT THOMAS  
KENNETH ELLENDER

P.O. Box 630 • Houma, LA 70361  
Tel: (985) 879-2495 • Fax: (985) 879-2283  
[www.tpcw.org](http://www.tpcw.org)

MICHAEL A. SOBERT  
*General Manager*

CECILIA PRADO NORMAN  
*Chief Administrative Officer*  
Jacob Prosperie  
*Chief Engineer*

## BOIL WATER ADVISORY

June 2, 2022


BWA2022-06-02

In accordance with the Louisiana Department of Health's Sanitary Code and out of an abundance of caution, 33 metered customers beginning at Mary Hughes Drive and all of Mary Hughes Circle are affected by this Boil Water Advisory. Please see the attached map for a more detailed graphic representation of the Boil Water Advisory area. Customers are advised to boil their water to a hard rolling boil for at least 1 minute prior to consumption. Please visit [www.ldh.la.gov](http://www.ldh.la.gov) or [www.tpcw.org](http://www.tpcw.org) for more specific detail information concerning what to do when a Boil Water Advisory has been issued.

A main waterline at the corner of Acadian and Mary Hughes Drive failed and the water had to be turned off to do the repair allowing the pressure to possibly drop below the required minimum of 20 psi.

Samples have been taken with results expected back before 5 pm on Friday, June 3, 2022.

Remember to boil your water in a hard rolling boil for at least 1 minute prior to human consumption. Please like, share, and follow us on Facebook for information concerning your drinking water supplier and the results of water quality sampling on testing of your water.

  
Michael A. Sobert  
General Manager 6/02/22



UnderAdvisory  
Under Advisory

**Boil Water Advisory**  
ALL OF MARY HUGHES CIRCLE  
FROM MARY HUGHES DRIVE

**EST. 33 CUSTOMERS**

**JUNE 2, 2022**

BWA\_2022-06-01

