



CHESTER P. VOISIN
President
JOHN PIZZOLATTO
Vice-President
CLIFTON J. STOUFFLET
Secretary

STEPHEN HORNSBY
VINCENT CELESTIN
CHARLES BROWN, SR.
TERI CHATAGNIER
WILBERT THOMAS
KENNETH ELLENDER

P.O. Box 630 • Houma, LA 70361
Tel: (985) 879-2495 • Fax: (985) 879-2283
www.tpcw.org

MICHAEL A. SOBERT
General Manager

CECILIA PRADO NORMAN
Chief Administrative Officer

JACOB PROSPERIE
Chief Engineer

June 10, 2022
BOIL WATER ADVISORY LIFTED
BWA 2022-06-02

Please be advised the Boil Water Advisory, BWA-2022-06-02, concerning the 106 customers located from 3027 Bayou Dularge Road to the end of Bayou Dularge Road as shown on the attached map is LIFTED. The 5 samples that were collected and tested have shown that the water contains no harmful bacteria and that it is safe for human consumption. The test results are attached for your use and verification. It is no longer necessary to boil your water for 1 minute in a hard boil before consuming. The water is safe to drink.

Please, like share and follow us on Facebook for notifications that affect your drinking water.

Michael A. Sobert
General Manger

MAS/jpp



Boil Water Advisory

EST. 106 CUSTOMERS

**FROM 3027 BAYOU DULARGE RD
TO THE END OF BAYOU DULARGE RD**

JUNE 9, 2022

BWA_2022-06-02



Houma Water Treatment Plant Service Area Boil Water Advisory Report for Thursday, June 09, 2022

Sample Location ID 1109001	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
3007 Bayou Dularge Rd	06-09-22	1.30	A	
3105 Bayou Dularge Rd	06-09-22	1.29	A	
3225 Bayou Dularge Rd	06-09-22	1.32	A	
3325 Bayou Dularge Rd	06-09-22	1.51	A	
3442 Bayou Dularge Road	06-09-22	1.24	A	

BWA-Main line leak repair required shutting off water to boil advisory area.

Date: 6-10-2022

Ray Percle

Ray Percle
Lab Supervisor