



CHESTER P. VOISIN
President
JOHN PIZZOLATTO
Vice-President
CLIFTON J. STOUFFLET
Secretary

STEPHEN HORNSBY
VINCENT CELESTIN
CHARLES BROWN, SR.
TERI CHATAGNIER
WILBERT THOMAS
KENNETH ELLENDER

P.O. Box 630 • Houma, LA 70361
Tel: (985) 879-2495 • Fax: (985) 879-2283
www.tpcw.org

MICHAEL A. SOBERT
General Manager

CECILIA PRADO NORMAN
Chief Administrative Officer

April 12, 2022
BOIL WATER ADVISORY LIFTED
BWA 2022-04-01

Please be advised the Boil Water Advisory, BWA2022-04-01, affecting the 10 customers located between Gage Court and 425 Bayou Blue Road is LIFTED. The two samples taken, copy of results are attached, show no harmful bacteria present and proves that the water is safe for human consumption. It is no longer necessary to boil your water for 1 minute in a hard boil before consuming. The water is safe to drink.

Please, like share and follow us on Facebook for notifications that affect your drinking water.


Michael A. Sobert
General Manager 4/12/22

Schriever Water Treatment Plant Service Area Boil Water Advisory Report for Monday, April 11, 2022

Sample Location ID 1109002	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
441 Bayou Blue RD	04-11-22	2.50	A	1.07
457 Bayou Blue RD	04-11-22	2.70	A	2.17
491 Bayou Blue Rd	04-11-22	2.80	A	2.26

BWA - Tie in line at Gage Court Bayou Blue for FEMA trailer park project

Date: 4-12-2022

Ray Percle

Ray Percle
Lab Supervisor