



CHESTER P. VOISIN
President
JOHN PIZZOLATTO
Vice-President
CLIFTON J. STOUFFLET
Secretary

STEPHEN HORNSBY
VINCENT CELESTIN
CHARLES BROWN, SR.
TERI CHATAGNIER
WILBERT THOMAS
KENNETH ELLENDER

P.O. Box 630 • Houma, LA 70361
Tel: (985) 879-2495 • Fax: (985) 879-2283
www.tpcw.org

MICHAEL A. SOBERT
General Manager

CECILIA PRADO NORMAN
Chief Administrative Officer

JACOB PROSPERIE
Chief

April 26, 2022
BOIL WATER ADVISORY LIFTED
BWA 2022-04-03

Please be advised the Boil Water Advisory, BWA2022-04-03, concerning the 8046 customers located in the Schriever/Gray area as shown on the attached map is **LIFTED**. The 33 samples that were collected and tested have shown that the water contains no harmful bacteria and that it is safe for human consumption. The test results are attached for your use and verification. It is no longer necessary to boil your water for 1 minute in a hard boil before consuming. The water is safe to drink

Please, like share and follow us on Facebook for notifications that affect your drinking water.


Michael A. Sobert

General Manager

4/26/22

Schriever Water Treatment Plant Service Area Boil Water Advisory Report for Monday, April 25, 2022

Sample Location ID 1109002	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
3164 Lillian Marie Drive; POC 259	04-25-22	3.12	A	
100 Timberwood Drive; POC 16	04-25-22	2.93	A	
129 Technology Lane; POC 240	04-25-22	3.52	A	
4255 West Park Ave; Rhett Place PS; POC 15	04-25-22	3.45	A	
Lumen Christi Court; POC 68	04-25-22	3.33	A	
2885 Gentle Oak Place; POC 247	04-25-22	3.18	A	
1407 Hwy 311; Fletcher Tech College; POC 230	04-25-22	3.83	A	
LA Hwy 311 @ Waterworks #3 MM; POC 10	04-25-22	2.71	A	
116 Deer Run Drive; POC 271	04-25-22	2.63	A	
1827 West Park Ave; Andrew Price Gym; POC 2	04-25-22	4.30	A	
247 West Park Ave @ Domino's Pizza; POC 213	04-25-22	3.90	A	
Calumet Street @ LA Hwy 20; POC 4	04-25-22	3.90	A	
540 West Main St; Bourgeois Market; POC 5	04-25-22	3.80	A	
1914 West Main St; St. Mark's Church; POC 11	04-25-22	4.10	A	
5058 West Main St; Dept of Trans; POC 21	04-25-22	3.10	A	
5521 West Park Ave @ Oakshire Drive; POC 22	04-25-22	3.60	A	
2550 Coteau Rd; Bayou Blue School; POC 20	04-25-22	3.70	A	
202 Nottoway Drive; POC 262	04-25-22	3.40	A	
205 South Ellendale Estates Blvd; POC 263	04-25-22	2.60	A	
2719 Savanne Road; POC 43	04-25-22	2.90	A	
4200 SD Mandalay Rd @ Tyos Ct; POC 280	04-25-22	2.80	A	
4968 North Bayou Black Drive; POC 284	04-25-22	2.10	A	
5149 Bayou Black Drive; Shell PS; POC 41	04-25-22	2.40	A	
5609 Bayou Black Drive; Crosstex; POC 40	04-25-22	2.20	A	
5904 North Bayou Black Drive; POC 286	04-25-22	1.80	A	
119 LA Hwy 20; POC 7	04-25-22	3.70	A	
1918 Bull Run Road; Chacahoula PS; POC 37	04-25-22	2.20	A	
1531 Hwy 20; POC 287	04-25-22	1.30	A	

Schriever Water Treatment Plant Service Area Boil Water Advisory Report for Monday, April 25, 2022

Sample Location ID 1109002	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
138 Azalea Drive; POC 147	04-25-22	1.70	A	
204 Fandal St @ Railroad Alley; POC 211	04-25-22	2.10	A	
6306 Bayou Black Drive; Gibson Tank; POC 39	04-25-22	2.30	A	
6213 Bayou Black Drive; POC 209	04-25-22	2.40	A	
499 Powhattan	04-25-22	2.10	A	

Pressure drop during generator load testing resulting in area pressure to drop below 20 psi.

Date: April 26, 2022

Ray Percle

**Ray Percle
Lab Supervisor**