



CHESTER P. VOISIN
President
JOHN PIZZOLATTO
Vice-President
CLIFTON J. STOUFFLET
Secretary

STEPHEN HORNSBY
VINCENT CELESTIN
CHARLES BROWN, SR.
TERI CHATAGNIER
WILBERT THOMAS
KENNETH ELLENDER

P.O. Box 630 • Houma, LA 70361
Tel: (985) 879-2495 • Fax: (985) 879-2283
www.tpcw.org

MICHAEL A. SOBERT
General Manager


CECILIA PRADO NORMAN
Chief Administrative Officer

February 9, 2022
BOIL WATER ADVISORY LIFTED
BWA 2022-02-01

Please be advised the Boil Water Advisory, BWA2022-02-01, concerning the 37 customers located in the area of 1000 Dunn to 1410 Center Street as shown on the attached map is LIFTED. The 3 samples that were collected and tested have shown that the water contains no harmful bacteria and that it is safe for human consumption. The test results are attached for your use and verification. It is no longer necessary to boil your water for 1 minute in a hard boil before consuming.

The water is safe to drink

Please, like share and follow us on Facebook for notifications that affect your drinking water.


Michael A. Sobert
General Manager 2/9/22

Schriever Water Treatment Plant Service Area Boil Water Advisory Report for Tuesday, February 08, 2022

Sample Location ID 1109002	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
1005 Dunn St	02-08-22	2.00	A	
1400 Dunn St	02-08-22	3.60	A	
1402 Schley St	02-08-22	3.70	A	

1005 Dunn St to 1410 Center St. Tunnel fire leg line valve installation.

Date: February 8, 2022

Ray Percle

Ray Percle
Lab Supervisor