



# State of Louisiana

Office of Public Health Laboratory  
1209 Leesville Avenue  
Baton Rouge, Louisiana 70802



---

**Submitter:** DHH-OPH Engineering Services  
628 N. Fourth Street  
Baton Rouge, LA 70821

**Attention:** Amanda Laughlin  
**Fax Number:** 225-342-8138

---

**Public Water Supply ID:** LA1109002  
**Point of Collection ID:** AME-002  
**Field Sample Description/ID:** ACR182  
**Field Specimen Description/ID:**  
**Date of Collection:** 6/6/2016  
**Time of Collection:** 10:15

**Lab Sample ID:** B1600108-004  
**Matrix Type:** Raw Source  
**Collection Type:** Ultrafilter  
**Volume Collected:** 101.1 L  
**Date Received:** 6/7/16  
**Date Reported:** 6/21/16

---

<u>Test</u>	<u>Result</u>	<b>Volume Analyzed: 101.1 L</b>
*Amoebae culture	Amoeba Absent	
*^Flagella Test	Not Performed	
* <i>Naegleria fowleri</i> PCR	<i>N. fowleri</i> DNA not detected	

**Reviewed by:** SJ/NWC

#### Disclaimer

\**Naegleria fowleri* is not currently a US EPA regulated drinking water contaminant, and there is no US EPA approved procedure for the detection of *N. fowleri* in drinking water. The amoebae culture, flagella test, and PCR test procedures used by the OPH Laboratory were derived from the peer reviewed literature and procedures provided by the CDC and other water laboratories. These results should be used for Investigational and Epidemiological Use Only.

^The Flagella test is an indicator of the likely presence of *Naegleria* spp. but cannot confirm the presence of *Naegleria fowleri*.