

Client: Terrebonne Parish Consolidated Waterworks District 1  
Analysis: *Naegleria Fowleri* (Culture/PCR)  
Project Name: PWS ID 1109002  
Client Sample ID: 4260 HWY665 PAC Marina Sample Date/Time: June 18, 2018 11:40  
BCS Sample ID: 1806152 Sample Description: Rexeed 25S Ultrafilter  
Date Received: June 19, 2018 11:30 Amount Submitted: 99.9 L % Solids: N/A  
Amount Analyzed: 99.9 L Receipt Temperature: 27.6 deg C Preserved: No  
Analysis Start: June 19, 2018 11:49 Analysis Stop Date: June 26, 2018 13:50  
Analyst: Katherine Sayler, Ph.D. Qualifier: #  
Primary Value: 1.0 Visual presence of Amoeba/Cysts (0 for absence/1.0 for presence)  
Secondary Value: 0 *Naegleria fowleri* DNA detection (0 for absence/1.0 for presence)

Analysis Notes: Active amoeba trophozoites visually not detected. Potential cysts visually detected. *N. fowleri* PCR assay was negative.  
*N. fowleri* was not detected in submitted sample.

BCS LABORATORIES, INC. — GAINESVILLE  
4609 NW 6TH STREET, STE. A, GAINESVILLE, FLORIDA 32609  
TEL. (352) 377-9272, FAX. (352) 377-5630  
WWW.MICROBIOSERVICES.COM

FL DOH #E82924, ISO/IEC 17025:2005 L2422 (ANAB), PA DEP# 68-03950, EPA# FLO1147  
THIS REPORT SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN CONSENT OF BCS LABORATORIES

