


Boil Water Advisory

EST. 1,762 CUSTOMERS

**FROM 4798 GRAND CAILLOU RD. & 4806 SHRIMPERS ROW
ALL THE WAY TO THE END OF DULAC AND FOUR POINT**



NOVEMBER 30, 2022

BWA-2022-11-03

Houma Water Treatment Plant Service Area Boil Water Advisory Report for Thursday, December 01, 2022

Sample Location ID 1109001	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
4798 Grand Caillou Road; Benoit PS; POC 75	12-01-22	2.70	A	0.59
5602 Shrimpers Row; POC 80	12-01-22	2.90	A	0.66
Shrimpers Row @ Combon Bridge; POC 79	12-01-22	3.00	A	0.73
6800 Shrimpers Row; POC 217	12-01-22	2.70	A	0.9
715 Shrimpers Row; Lower Dulac Bldg; POC 225	12-01-22	2.50	A	0.75
8989 Shrimpers Row; POC 301	12-01-22	2.40	A	1
6701 Grand Caillou Rd; Addie Ct; POC 212	12-01-22	2.90	A	0.72
7587 Grand Caillou Road; POC 222	12-01-22	2.70	A	0.78
9570 Grand Caillou @ Berwick Bay; POC 304	12-01-22	1.40	A	0.68
Four Point Master Meter; POC 126	12-01-22	2.18	A	1.07
1140 Four Point Rd; POC 303	12-01-22	.70	A	0.56

Water pressure may have dropped below 20 psi during water main repair requiring a Boil Water Advisory.

Date: December 2, 2022

Ray Percle

**Ray Percle
Lab Supervisor**