



GENERAL INFORMATION

The Board of Commissioners conducts its public meetings twice per month in the Main Office Board Room at 8814 Main Street, Houma, Louisiana at 5:30 PM on the first and third Mondays of each month. Meetings may be re-scheduled or cancelled for conflicts or holidays as the Board of Commissioners deems necessary.

Water quality is tested throughout the year to adhere to strict guidelines and regulations set forth by Consolidated Waterworks District No. 1, the State of Louisiana Department of Health and the Federal EPA. Consolidated Waterworks is committed to serving safe clean water to all of its customers. The Environmental Protection Agency has mandated that community water systems annually inform their customers of the quality of water delivered by the system. Consolidated Waterworks District No. 1 is also required to inform you of certain risks and possible contaminants that may be contained in drinking water.

Consolidated Waterworks District No. 1 currently operates two independent water treatment plants distributing water to separate sections of Terrebonne Parish. Under certain emergency conditions, water may come from either plant. The primary difference between the two plants is the water source. Both plants utilize the coagulation, sedimentation, filtration, and disinfection process to treat the surface source water. Granular activated carbon and sand filters are utilized to filter water and adsorb many organic and some inorganic compounds. This adsorption process greatly enhances the water's taste and odor characteristics. Chlorine is the primary plant disinfectant. Chloramine disinfectant is injected prior to water entering the distribution system.

INFORMATIONAL STATEMENTS and WARNINGS

1. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.
2. Contaminants that may be present in source water include:
 - a. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - b. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
 - c. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
 - d. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
 - e. Radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.
3. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.
4. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.
5. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

6. Some people who drink water containing trihalomethanes or haloacetic acids in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system and may have an increased risk of getting cancer.
7. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing components. Consolidated Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in

plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

WATER SOURCES

SCHRIEVER WATER TREATMENT PLANT:

PRIMARY: Surface Water from Bayou Lafourche. The bayou runs from Donaldsonville, LA to the Gulf of Mexico. The bayou obtains most of its water from the Mississippi River @ Donaldsonville, LA.

HOUMA WATER TREATMENT PLANT

PRIMARY: Surface Water from Gulf Intracoastal Waterway (generally flows east/west along coastal Louisiana and other Gulf states: rain water runoff, Mississippi River influence, Atchafalaya River influence, and tidal water influence)

SECONDARY: Bayou Black (when the Intracoastal Canal becomes too salty: chlorides greater than 250 ppm)

SOURCE WATER ASSESSMENT: A source water assessment has been performed for both the Schriever & the Houma Water Treatment Plants. The reports and the area maps may be viewed at Consolidated Waterworks District No. 1's office at 8814 Main Street, Houma, LA

See Table on Reverse Side

2022 CONSUMER CONFIDENCE REPORT (FOR CALENDAR YEAR 2021)

DEFINITIONS: to assist you in understanding the Consumer Confidence Report.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL: Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

N.D.: Non Detected: An analytical sample where the contaminant could not be detected by the method used by the laboratory.

ppm: Parts per Million: One part per million corresponds to 1 minute in 2 years or a single penny in \$10,000.00

ppb: Parts per Billion: One part per billion corresponds to 1 minute in 2000 years or a single penny in \$10,000,000.00

pCi/L: Picocuries per Liter is a measure of the radioactivity in water.

NTU: Nephelometric Turbidity Units: Is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

AL: Action Level: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

QUESTIONS ABOUT THE CCR;
Contact Ray Percle
(985) 879-2495 or (985) 448-1576



TABLE of CONTAMINANTS and OTHER WATER QUALITY PARAMETERS

The EPA register mandates that ALL DETECTED CONTAMINANTS be included in the CCR whether or not the level detected meets or exceeds the MCL or MCLG.
The following table lists the detected contaminant levels of Consolidated Waterworks District No.1 drinking water for samples collected and analyzed in calendar year 2021.

CONTAMINANT	TREATMENT PLANTS PUBLIC WATER SYSTEM ID Numbers				UNITS	MCLG	MCL	Violation Yes/No	Major Sources in Drinking Water
	HOUMA PWS ID 1109001		SCHRIEVER PWS ID 1109002						
	MAXIMUM	LOW %	MAXIMUM	HIGHEST					
Clarity Turbidity (Plant)	0.59	97	9.99	97	NTU	N/A	0.3	No	Soil Runoff
<small>Turbidity measures cloudiness of the water and is a good indicator of the effectiveness of the filtration system. Low% is lowest monthly percentage of samples meeting requirements specified for treatment technology. Value without violation >95%</small>									
MICROBIOLOGICAL	Houma 110 Samples/mo. NO. of POSITIVES HIGHEST Positive MO. %		Schriever 100 Samples/mo. NO. of POSITIVES HIGHEST Positive MO. %		UNITS	MCLG	MCL		Major Sources in Drinking Water
Total Coliforms	0	0	0	0	Positive	0	See Below	No	Sewerage treatment plants; septic system runoff; livestock operations; wildlife
Fecal Coliform and E. coli	0	0	0	0	Positive	0	See Below	No	Human and animal fecal waste
<small>The MCL: presence of coliform bacteria > 5% of monthly samples. The MCL: a routine sample & a repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive.</small>									
VOLATILE ORGANICS Stage II (latest EPA rule)	Data From 4 Sample Sites MAXIMUM LRAA QRTL Y RANGE		Data From 8 Sample Sites MAXIMUM LRAA QRTL Y RANGE		UNITS	MCLG	MCL		Major Sources in Drinking Water
Total trihalomethanes (THM's)	67.7	19.6-68.5	53.0	16.9-79.4	ppb	0	80	No	By-product of drinking water chlorination.
Haloacetic Acid (HAA5's)	38.8	10.0-39.0	34.2	11.9-60.0	ppb	0	60	No	By-product of drinking water chlorination.
SYNTHETIC ORGANIC CONTAMINANTS	MAXIMUM	RANGE	MAXIMUM	RANGE	UNITS	MCLG	MCL		Major Sources in Drinking Water
Simazine	ND	ND(2 taken)	0.073	ND-0.073(2 taken)	ppb	4	4	No	Chlorinated Herbicides; Runoff from weed control
Atrazine	0.096	0.073-0.096(2 taken)	0.14	0.067-0.14(2 taken)	ppb	3	3	No	Chlorinated Herbicides; Runoff from weed control
Daipon	0.40	0.38-0.40(2 taken)	ND	(2 taken)	ppb	200	200	No	Chlorinated Herbicides; Runoff from weed control
INORGANIC CONTAMINANTS	90 th PER-CENTILE (2020)	RANGE 30 Samples	90 th PER-CENTILE (2019)	RANGE 30 Samples	UNITS	MCLG	MCL	Sites Over AL	Major Sources in Drinking Water
Lead (Lead/Copper Program)	0.001	ND-.005	0	ND	ppm	0	AL=.015	0	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper (Lead/Copper Program)	0.4	ND-0.7	0.3	ND-1.5	ppm	1.3	AL=1.3	1	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
INORGANIC CONTAMINANTS	MAXIMUM	RANGE	MAXIMUM	RANGE	UNITS	MCLG	MCL		Major Sources in Drinking Water
Aluminum	0.05	0.05(one taken)	0.03	0.03(one taken)	ppm	0.05	0.2	No	Erosion of natural deposits(Secondary drinking water regulation)
Potassium	3.1	3.1 (one taken)	2.5	2.5 (one taken)	ppm	NA	NA	NA	Erosion of natural deposits
Sulfate	54	54(one taken)	58	58 (one taken)	ppm	250	250	No	Erosion of natural deposits(Secondary drinking water regulation)
Fluoride	0.7	0.7 (one taken)	0.8	0.8 (one taken)	ppm	1.2	4	No	Erosion of natural deposits; added to water supply to reduce tooth decay
Nitrate-Nitrite	0.2	0.2 (one taken)	0.5	0.5(one taken)	ppm	10 / 1	10 / 1	No	Runoff from fertilizer use; leaking from septic tank, sewage
Sodium	26.4	24.4 (one taken)	18.2	18.2 (one taken)	ppm	250	250	No	Erosion of natural deposits
Chloride	36	36(one taken)	29	29 (one taken)	ppm	250	250	No	Erosion of natural deposits(Secondary drinking water regulation)
RADIOACTIVE CONTAMINANTS	MAXIMUM	RANGE	MAXIMUM	RANGE	UNITS	MCLG	MCL		Major Sources in Drinking Water
Combined Radium (226+228)	1.55	1.55	1.44	1.44	pCi/L	0	5	No	Erosion of natural deposits;oil and gas production; mining
Gross alpha particul activity	2.92	2.92	2.68	2.68	pCi/L	0	15*	No	Erosion of natural deposits;oil and gas production; mining
Gross beta particul activity	3.84	3.84	1.46	1.46	pCi/L	0	50*	No	Erosion of natural deposits;oil and gas production; mining
<small>* EPA considers 50 pCi/L to be the level of concern for Beta particles and 15 pCi/L for Alpha particles.</small>									
DISINFECTANT/OXIDANTS	AVG.	RANGE	AVG.	RANGE	UNITS	MRDL	MRDLG		Major Sources in Drinking Water
Chlorine (disinfection leaving plant)	3.70	1.0-4.5	3.55	0.1-4.6	ppm	4	4	No	Disinfectant added at the treatment plant; maintains at least a 0.5 ppm residual at furthestmost point of distribution system
Chlorine dioxide ¹	Max. Daily	RANGE	Max. Daily	RANGE	ppm	0.8	0.8	Yes ¹	Strong oxidant added to oxidize organics
	0.22	0.02-0.22	0.32	0.01-.032					
Chlorite ion	Monthly AVG.	RANGE	Monthly AVG.	RANGE	ppm	1	1	No	Degradation of chlorine dioxide
	0.03	0.2-0.4	0.03	0.02-0.04					
Chlorite ion	HIGH MO. AVG.	RANGE	HIGH MO. AVG.	RANGE	ppm	1	1	No	Degradation of chlorine dioxide
	0.127	0.010-0.127	0.094	0.010-0.094					
TOTAL ORGANIC CARBON REMOVAL (TOC)	LOWEST QTRLY RAA	MONTHLY RANGE	LOWEST QTRLY RAA	MONTHLY RANGE	UNITS	MCLG	MCL		Major Sources in Drinking Water
TOC Removal	1.63	1.63-1.89	1.77	1.77-1.97	(ratio)	n/a	1.0 **	No	Organic Carbon results from decomposed organic matter present in water sources
<small>** Ratio of the actual TOC removal compared to the required removal by regulation (lowest quarterly running annual average must be above 1.0 to avoid violation)</small>									
GENERAL CHEMISTRIES	YEARLY AVG.		YEARLY AVG.		UNITS	MCLG	MCL		Major Sources in Drinking Water
Turbidity (Distribution)	0.72		0.61		NTU	N/A	N/A	n/a	Sediment in water distribution lines
Chloramine Residual (Distribution)	HIGH QRAA	QRTL Y RANGE	HIGH QRAA	QRTL Y RANGE	ppm	4	4	No	0.5 Minimum Chloramine Residual at Furthestmost Point in Distribution System
	3.30	2.28-3.30	3.40	1.69-3.40					
Fluoride	YEARLY AVG.	RANGE	YEARLY AVG.	RANGE	ppm	1.2	2	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories
	0.77	0.45-1.41	0.80	0.20-1.23					
Hardness	YEARLY AVG.	RANGE	YEARLY AVG.	RANGE	ppm	n/a	n/a	n/a	Naturally occurring dissolved calcium and magnesium salts in the source water.
	91	40-160	137	72-200					
UCMR4 RESULTS	HWTP April 2018- November 2020	Range	SWTP November 2019- August 2020	Range	UNITS	MINIMUM REPORTING LEVEL			UCMR4 - The 1996 amendments to the Safe Drinking Water Act requires that the EPA establish criteria to monitor unregulated contaminants. Up to 30 contaminants may be monitored every five years. UCMR4 is the fourth effort of this monitoring. There are currently no MCLG's for these contaminants. Contaminants tested are NOT currently regulated. UCMR testing monitors contaminants in drinking water and untreated source water.
Manganese (Entry Point to System)	1.55	<0.400-2.23	1.99	1.22-3.83	ppb	0.400	n/a	n/a	Erosion of natural deposits(Secondary drinking water regulation)
HAA9 (Haloacetic Acid) Distribution System	28.33	17.20-57.65	12.53	2.08-32.17	ppb	0.2-0.5	n/a	n/a	By-product of drinking water chlorination.
Raw/Unprocessed Source Water									
Bromide	196.0	34.7-1220	43.6	29.0-53.3	ppb	20.0	n/a	n/a	Erosion of natural deposits and saltwater intrusion
Total Organic Carbon	8035	4950-10800	3788	3320-4420	ppb	1000	n/a	n/a	Organic Carbon results from decomposed organic matter present in water sources
(LT2) LONG TERM 2 ENHANCED SURFACE WATER TREATMENT RULE	No. of SAMPLES 48	No. DETECTED 2	No. of SAMPLES 24	No. DETECTED 1	UNITS	MCLG	Action level		Cryptosporidium is a microbial parasite found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most common filtration methods cannot guarantee 100 percent removal. Monitoring indicates the presence of these organisms in some of our source water. Current test methods do not determine if the organisms are dead or if they are capable of causing disease. Based on Cryptosporidium results, the Houma system is required to provide an additional 1-log treatment for Cryptosporidium no later than 4/1/2023.
Sampling Performed on Plants' Raw Water Sources	Sampling period (2016-2018)	Results Range 0.1-1.4	Sampling Period (2015-2017)	Results Range 0-0.1	Oocysts/liter	zero	12 month LRAA>0.075		

¹During the period covered by this report, the noted violation of drinking water regulations occurred.

COMPLIANCE PERIOD
Schriever Water Treatment System 4-1-2021 to 4-30-2021

ANALYTE
Chlorine Dioxide

TYPE
Tier 3 Monitoring

Notification
Direct Mail and
CCR 2022

Public Notification: The Schriever Water Treatment System is in violation for failing to monitor chlorine dioxide and chlorite as set forth by the State (Part XII of the Louisiana State Sanitary Code (LAC 51:111) and the Federal Drinking Water Regulations (CFR Part 141). We are required to monitor your drinking water for chlorine dioxide and the disinfection by product chlorite daily at the entry point to the distribution system. On April 19 2021, Schriever Water Treatment failed to collect three additional samples in the distribution system the day following a chlorine dioxide exceedance to ensure the quality of drinking water at that time. The Schriever Water Treatment System was assessed a monitoring violation for chlorine dioxide for the time period 4-1-2021 to 4-30-2021. Necessary action has been taken to prevent this violation from recurring.